

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 2647

Dated: 24.08.2026

It is certified that an inspection team headed by PRITI GOSWAMI

(Name of Officers with designation) from CHEMIST.....PHED

inspected the GOKULDAS PUBLIC SCHOOL, BISTAN ROAD KHARHONE

(Name & Address of the school) on 20-8-2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 222..... dated 21-8-2026

of (PHED Lab) certified that

the GOKULDAS PUBLIC SCHOOL, KHARHONE (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till Three months

Signature with Seal:

Name

Designation

Name & Address of the Office / Department:

Executive Engineer,

Public Health Engineering Dn.

KHARGONE (M.P.)

To PRINCIPAL,

GOKULDAS PUBLIC SCHOOL

(Name & Address of the Institution)

KHARGONE (M.P.)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

**District Water Testing Laboratory,
Public Health Engineering Department.
Diversion Road, Khargone, 451001, Phone-07282-232875
Test Report**

Format No. DWTL/PHED/KGN 14

Nature of sample :- Drinking Water Sample / Others	Sample Not collected By Distt.Lab	Unique Identification No.	81/01
To, The Principal, GOKULDAS PUBLIC SCHOOL Bistan Road Khargone m.p..	Sender's letter no.	GPS/2026-27/24	Sender's letter Date
	DWTL Ref. No	222	DWTL Receipt date
	Date of analysis started	20.08.2026	Date of analysis completed
	Quantity Of Sample	1 liter	


Sample Details

No.	Particulars of Samples
1	Drinking Water Sample From The Gokuldas Public School RO System
2	—
3	—
4	—
5	—

Sample details

No.	Characteristics ,unit and test methods	BIS -10500:2012		RESULTS				
		Desirable Limit	Permissible Limit	1	2	3	4	5
1	Free Residual Chlorine	0.2	1.0	Nil		-	-	-
2	Colour in Hazen scale	5	15	Agreeable		-	-	-
3	Odour	Agreeable	Agreeable	Agreeable		-	-	-
4	Iron as Fe in mg/l, IS 3025, Part -53	1.0	1.0	-		-	-	-
5	Nitrate as NO3 in mg/l, APHA 23 rd Edition	45	45	-		-	-	-
6	Fluoride as F in mg/l IS 3025, Part --60	1.0	1.5	Nil		-	-	-
7	Chloride as Cl in mg/l, IS 3025, Part-32	250	1000	28.2		-	-	-
8	Total Alkalinity as CaCO ₃ in mg/l, IS 3025, Part -23	200	600	46.4		-	-	-
9	Calcium as Ca++, in mg/l, IS 3025, Part -40	75	200	20.2		-	-	-
10	Magnesium as Mg++, in mg/l, APHA 23 rd Edition	30	100	11.2		-	-	-
11	Sulphate as SO ₄ in mg/l, BIS:3025 (Part -24)	200	400	Nil		-	-	-
12	pH APHA 23 rd , Part -11	6.5 to 8.5	6.5 to 8.5	6.68		-	-	-
13	Turbidity in NTU, IS 3025, Part-10	1.0	5.0	Nil		-	-	-
14	Total Hardness as CaCO ₃ in mg/l, IS 3025, Part-21	200	600	111.1		-	-	-
15	Conductivity at 25°C in micromhos /cm, IS 3025, Part-14	-	-	258		-	-	-
16	TDS By meter IS 3025, Part-16	500	2000	120		-	-	-
17	Phenolphthalein Alkalinity as CaCO ₃ in mg/l IS 3025, Part	-	-	-		-	-	-
18	Faecal Coliform (TTC) per 100 ml IS APHA23 rd edition, 9211 B	NIL		-		-	-	-
19	Total coliform per 100 ml IS APHA23 rd edition 9211 B	NIL for treated water and water in distribution system		Nil		-	-	-

1. This report should not be produced partly or full without approval of signatory authority for legal purposes.
2. It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but upto the limits indicated under the "permissible limit in the absence of alternate source" in column 4, above which the sources will have to be rejected.
3. The results refer only to tested samples and parameters tested
4. Samples will be stored for a period of 10 days from the date of issue of report.



Chemist
DISTRICT LABORATORY
P. H. E. DEPARTMENT KHARGONE